

# Case Study of ESCO for General Hospital

at Le Meridien, on 14-15<sup>th</sup> January 2010

Asia ESCO Conference 2010 in India

Yamatake Corporation

Speaker : Shinsuke Okochi of Yamatake Corporation

The logo for azbil, featuring the word "azbil" in a bold, lowercase, red sans-serif font.

# Outline of Case Study Building

Allowed for This Conference Use Only

Name : Kyouritsu Kanbara General Hospital

Location : Shizuoka Prefecture

GFA : 22,086 m<sup>2</sup> 5F + 1BF

Capacity : 330 Beds

Completion Date : April, 1983




Energy Consumption ( Average for past 3 years before ESCO )

Electrical Power : 4,132,122 kWh / Year

City Natural Gas : 656,536 Nm<sup>3</sup> / Year

Approx. : **58,600** [GJ/Year]

## Serious Issues to be resolved



## ESCO

Deterioration  
of  
Facilities

Refurbishment

Negative Change in System  
of  
Medical Service Fee

Cost Saving

Social Responsibility  
as  
Regional Hospital

Contribution  
to  
Environmental Issues


# Proposal at Open Competition



Allowed for This Conference Use Only



No.	Energy Saving Measures	Description
1	Co-Generation + Heat Recovery	Existing Gas Fired Boiler replaced with Gas Co-Generation. Waste Heat Recovery utilizing for Absorption Chiller & Steam Boiler
2	Steam Supply Control	Install Control Valve close to header to minimize heat dissipation from steam piping
3	High Efficiency Motor	Existing motor for pumps replaced with High Efficiency Motor
4	VWV of secondary C/H water	Supply pressure control by Inverter provided with Chilled / Hot Water loop
5	Intermittent Running of FA-AHU	Fresh Air AHU operated by CO <sup>2</sup> density in concerned space
6	High Thermal Resistant Insulation	Hot water storage tank insulated with HTRI

Cumulative for & Years





**Guaranteed ESCO Contract :**  
**Saving Cost per Year = 48,000 KJPY/Y**  
**Contract Term : 6 Years**  
**ESCO Fee : 17,500 KJPY/Y**

# Planned Goal of Cost Saving



Allowed for This Conference Use Only

# Planned Goal of Energy Reduction



CO<sub>2</sub> emission reduction  
**895** [t-CO<sub>2</sub>/Year]

Allowed for This Conference Use Only

# Natural Gas Engine Co-generation

**azbil**

**New Installation**



- Co-Generation Plant (Lean Burn Mirror Engine) 350kw x 2 units.
- Approximately 70% of peak demand covered as backup emergency generator when black out

**Allowed for This Conference Use Only**





# Waste Heat Recovery Boiler

## Replacement with Improvement



External View

Before After



- Waste Heat Recovery Steam Boiler (0.2t) x 2
- Backup Gas Fired Boilers (2t) x 1

Allowed for This Conference Use Only

# Waste Heat Recovery Type Absorption Chiller **azbil**

Replacement to High Efficiency Equipment




External View

**Gas Fired Absorption Chiller with built-in waste heat recovery hot water used re-generator x 1 (Cooling capacity 216RT)**

Before


After



Rated capacity

205 RT

216 RT



Allowed for This Conference Use Only



# High Efficiency Motors with VVVF




External View

Improvement

- Replace with high efficiency motor pump
- Inverter control of chilled and hot water secondary pump

Allowed for This Conference Use Only

# Relationship with Customer thru BEMS



## - Contents of ESCO Service Contract -

- Intended Facilities : Connected to ESCO
- Daily maintenance done by Hospital
- Troubleshooting done by ESCO on call
- Periodical Rough Inspection
- Full Maintenance including Overhaul, if needed

# BEMS Configuration


Allowed for This Conference Use Only



Data Sharing & Feed Back  
between  
Customer & ESCO

Energy Data

Operation Data



\* BEMS introduced previous year before ESCO

# Data Visualization thru BEMS



Allowed for This Conference Use Only

BUILDING SCOPE azbil  
 運用評価 エネルギー 温熱環境 原単位・CO2 設定

## Monthly Energy Consumption

Kyoritsu Kanbara General Hospital

2006年 11月 表示  
 月 期間  
 2006年11月 2006年11月1日～2006年11月30日

Energy	Meter	Unit	Cons. Nov.2006	前月	前年	増減
Electricity	受電電力量(本館)	kWh	120882.0			
Electricity	本館一般動力(1)電力量	kWh	15314.0			
Electricity	本館一般動力(2)電力量	kWh	7982.0			
Electricity	本館保安動力(1)電力量	kWh	25973.0	29139.0	25439.0	-11%
Electricity	本館保安動力(2)電力量	kWh	23953.0	34004.0	20166.0	+18%
Electricity	本館電灯(1)電力量	kWh	16031.0	17131.0	16827.0	-5%
Electricity	本館電灯(1)2電力量	kWh	10482.0	11349.0	11191.0	-8%
Electricity	本館電灯(2)1電力量	kWh	8503.0	8728.0	9980.0	-15%
Electricity	本館電灯(2)2電力量	kWh	23929.0	24551.0	23489.0	+2%
Electricity	本館電灯(3)1電力量	kWh	13486.0	13422.0	15113.0	-11%
Electricity	本館電灯(3)2電力量	kWh	11631.0	11735.0	11286.0	+3%
Electricity	透折一般動力電力量	kWh	7353.0	7858.0	7940.0	-7%
Electricity	透折一般動力電力量	kWh	4424.0	4515.0	4349.0	+2%
Electricity	透折一般電灯電力量	kWh	2229.0	2411.0	2390.0	-5%

Electricity / Gas Consumption


BUILDING SCOPE azbil  
 運用評価 エネルギー 温熱環境 原単位・CO2 設定

## Energy Meter Yearly Consumption

Kyoritsu Kanbara General Hospital

本館一般動力(1)電力量 表示

メータ 計量ポイント 期間  
 本館一般動力(1)電力量 000102002 2004年度～2006年度



月	2004年度	2005年度	2006年度
4月	14,131	14,819	13,919

Point-wise Energy Comparison

BUILDING SCOPE azbil  
 運用評価 エネルギー 温熱環境 原単位・CO2 設定


## Carbon Dioxide (CO<sub>2</sub>) Yearly Emission

Kyoritsu Kanbara General Hospital

2005年度 表示

年度  
 2005年度

二酸化炭素(CO<sub>2</sub>)排出量(多年)



Carbon dioxide Emission Report

BUILDING SCOPE azbil  
 運用評価 エネルギー 温熱環境 原単位・CO2 設定

## Room Comfort

Kyoritsu Kanbara General Hospital

2006年 11月 30日 室内 表示

期間 指定時間帯 室内気流[m/s] 活動量[met]  
 2006年11月30日(木) 9時～18時 0.2 1.0

室内名	快適度	平均PMV	1 2 3 4 5 6					
			1	2	3	4	5	6
本館1階事務室	快適	0.0	-	-	-	-	-	-
本館外来診察室	無効	-	-	-	-	-	-	-
本館検査室	無効	-	-	-	-	-	-	-
本館厨房	無効	-	-	-	-	-	-	-
本館線室	無効	-	-	-	-	-	-	-
本館3F西側病室	快適	-0.1	-	-	-	-	-	-
本館4F西側病室	無効	-	-	-	-	-	-	-
本館中央材料搬運室	快適	0.5	-	-	-	-	-	-
本館4階東側	快適	-0.5	-	-	-	-	-	-
本館3F東側病室	快適	-0.1	-	-	-	-	-	-
本館医局	快適	0.3	-	-	-	-	-	-
本館リフト	無効	-	-	-	-	-	-	-
本館臨床検査室	無効	-	-	-	-	-	-	-
本館市営講義撮影室	無効	-	-	-	-	-	-	-

Monitoring of Comfort




# Follow-UP by ESCO

Allowed for This Conference Use Only

**azbil**

- Continuous PDCA cycle as ISO9001 will enable further improvement based on Objective Analysis as per real data given by BEMS !



# Intermittent Result



Allowed for This Conference Use Only

## Financial Result for Last 3 Years

Year	Initial Investment				Base Line (D)		Actual (E)		Balance (F)=(D)-(E) = Saving		ESCO Service Fee		Actual Cost Saving	
	Investment	Subsidy (1/2)	Actual Investment (C)=(A)-(B)											
	(A)	(B)	Exchange Rate =	90 JPY/US\$	Utility Cost		Utility Cost		Utility Cost					
	M-JPY	M-JPY	M-JPY	M-US\$	M-JPY	M-US\$	M-JPY	M-US\$	M-JPY	M-US\$	M-JPY	M-US\$		
2005	260	130	130	1.4	128	1.426	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2006	N/A	N/A	N/A	N/A			68.3	0.759	60.1	0.667	17.5	0.194	42.6	0.47
2007	N/A	N/A	N/A	N/A			51.1	0.568	77.3	0.858	17.5	0.194	59.8	0.66
2008	N/A	N/A	N/A	N/A			49.7	0.552	78.7	0.874	17.5	0.194	61.2	0.68
<b>Average Cost Saving</b>												<b>54.5</b>	<b>0.61</b>	
<b>Pay Back Period</b>												<b>2.4 Year</b>		

## Result of CO<sub>2</sub> Reduction for Last 3 Years

As regional hospital, awareness campaign made to community

Year	CO2 Emmission			
	Ton-CO2/Year			Reduction %
	Base Line	Actual	Balanace	
2005	3,475.4	N/A	N/A	N/A
2006		2528.4	947.0	27.2%
2007		2408.5	1,066.9	30.7%
2008		1776.4	1,699.0	48.9%



42inch LED Display at Waiting Room



Exclusive User Website



Literature

- Investment recovery has already done because unit price of city gas became almost half comparing with plan
- CO<sub>2</sub> reduction shall be reported when subsidy taken



# Thank you for your attention !!

## Contact us.

- (Tentative Name) Azbil Yamatake Private Limited. HQ Mumbai



Tel : T.B.D  
Fax : T.B.D



T.B.D

- Yamatake India Representative Office: ( Until Private Limited Established )  
First India Place 2nd Floor, Block-B, Sushant Lok-1 ,  
Mehrauli Gurgaon Road, Gurgaon-122002, Haryana, India



Tel +91-124-402-8979  
Fax +91-124-402-8800



sotoda@yamatake.co.in

- azbil Yamatake Corporation :



Tel : +81-3-6810-1107  
Fax : +81-3-5796-0794



<http://www.yamatake.com/> >>>> Contact Us